C-49

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का अमृत महोत्सव

No. F6/DFS/MS/School/2026/73

Dated: 23/01/2026

To,

Ms. Nikita,
Vice Principal/HoS.
Rajkiya Pratibha Vikas Vidyalaya,
Link Road, Plot No.1, Jhandewalan,
New Delhi – 110005.

Sub: Regarding renewal of FSC in r/o Rajkiya Partibha Vikas Vidyalya located at Plot No. 01, Link Road, Jhandewalan, New Delhi.

Sir,

Please refer to letter No. RPVV/LKRB/2025/156 dated 17.09.25, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on **16/10/2025** in the presence of **Mohd. Iftekhar Alam, Teacher** and following shortcomings were observed: -

1. Hose reel pipes found damaged and nozzles found missing.
2. Fire pump provided on terrace found non-functional.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours faithfully,

23/1/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy To: -

1. Director of Education, Government of NCT of Delhi, Old Secretariat, Civil Lines, Delhi -110054.