C-41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2025/SZ/797 Dated: 04/11/2025

To,

The Manager,
R.D. Rajpal School
Sec. 09, Dwarka, New Delhi- 110077

Sub: - Regarding renewal of "FSC" from fire safety point of view in r/o R.D. Rajpal School at Sec. 09, Dwarka, Delhi- 110077.

Sir,

Please refer to your letter No. AWS/DWK/2025/0279 dated 17.09.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 16.10.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Alka (Manager) was present and it was observed that school building having 02 blocks, namely New block is comprised of basement, ground plus three upper floors and old block is comprised of ground plus three upper floors, and have following shortcomings:-

1. Terrace fire pump of 450 LPM found provided but not functional in auto mode in old blk.
2. Overhead water storage tank provided in both blocks but found tank leakage in old blk.
3. Exit signage's are found removed at some places.

In view of the above, renewal of 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the school management.

Yours faithfully

4/11/25
(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.