C/148

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/441 Dated: -08/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi - 110001.

Sub: Regarding issuance of FSC in r/o M/s Ricky Dx. Guest House, 1242, Bazar Sangatrashan, Paharganj, New Delhi - 110055.

Sir,

This has reference to online application ID No. 2026042205534 dated 22/04/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on 29/04/2026 in presence of Sh. Ravi Kapoor, Owner to verify the compliance of shortcomings issued by this office vide letter No. F6/DFS/MS/GH/NDZ/2026/341 dated 21/04/2026 (copy enclosed) and found that the shortcomings are not complied in totality.

In view of above, the application for issuance of fire safety certificate cannot be considered at this stage & stands **rejected**. Further, the occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

Encl.: As above

8/5/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

O/C BH

Copy to:

1. The Manager, M/s Ricky Dx. Guest House, 1242, Bazar Sangatrashan, Paharganj, New Delhi - 110055.

C/148 140

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/341

Dated: 21/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Ricky Dx. Guest House, 1242, Bazar Sangatrashan, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026032003230 dated 20/03/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 04/04/2026 in the presence of Sh. Ravi Kumar, Owner and following shortcomings were observed: -

1. Public Address System provided but found non-functional.
2. Fire Pump on terrace found removed.
3. Overhead Water Storage tank capacity was 2,000 Ltrs against required capacity of 5,000 Ltrs.
4. Exit Signages found removed.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

20/4/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

O/C BP

Copy to: -

1. The Manager, M/s Ricky Dx. Guest House, 1242, Bazar Sangatrashan, Paharganj, New Delhi - 110055.