GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2026/ 192

Dated 03/03/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o Roastery Coffee (A Unit of NAI Coffee Private Limited) located at B – 74A, Ground floor, Sarvodaya Enclave, New Delhi – 110017.

Sir,

This has a reference to MHA application No. 2026020201153 dated 02/02/2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 13/02/2026 in the presence of Mr. Proloy Chakrabirty (Manager) and observed that building comprised of Basement, Ground plus one upper floor, Restaurant running on Ground floor only. Following shortcomings were observed during time of inspection:

1. Door size of 1.05 & 1.20 meter provided against requirement of 1.50 meter each.
2. First-Aid-Hose Reel not provided.
3. MOEFA are not provided.
4. Internal Hydrants not provided.
5. Terrace level fire pump capacity of 450 LPM not provided.
6. Overhead tank of capacity 20,000 litters not provided.
7. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

3/3/26

A. K. Malik
Dy. Chief Fire Officer
Delhi Fire Service
O/C (W)