GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/GH/2025/SZ/ 389 Dated: 16 /09 /2025

To

The Commissioner,
Municipal Corporation of Delhi,
E-1, 9th Floor, Dr. SPM Civic Centre,
Minto Road, New Delhi–110002
Email ID commissioner@mcd.nic.in

Subject: Regarding issuance of Fire Safety Certificate in r/o M/s Rosette Guest House at 8708, DBG Road, Pahar Ganj, New Delhi

Sir,

This has reference with **MCD Portal 2025081812570 dated 18/08/2025** on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 09/09/2025 in the presence of Mr. Omdutt Bhardwaj (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations: -

1. Electrical meter installed under the staircase is not allowed.
2. Terrace level firefighting pumps found faulty /defective and not on auto mode.

In view of above Shortcomings, the application for issuance Fire Safety Certificate **is rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

16/9/2025

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE