C-7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2025/School/ 845 Dated: 27 / 11 /2025

To

The Principal
R.S.M Public School
A-34, Gali No-1, Prem Nagar-III,
Kirari Suleman Nagar, Delhi-86.

Sub: - Regarding grant of fire safety certificate in r/o R.S.M Public School at A-34, Gali No-1, Prem Nagar-III, Kirari Suleman Nagar, Delhi-110086.

Sir,

Please refer to your letter no- 024 dated 09/10/2025 received in this department vide outdoor dairy no.6898 dated 09/10/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 14/11/2025 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 02 upper floors only. At the time of inspection Sh. Rahul Saharan (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. 01 nos. of staircases having width 1.10m is provided against the requirements of 1.50m each and both staircases must continue to terrace.
2. The class rooms door having width of 1.10m against the requirement of 1.20m.
3. Fire extinguishers are not provided.
4. Hose reel hose is not provided.
5. Terrace level fire pump capacity of 450 LPM is not provided.
6. Terrace level fire water tank capacity of 10,000 Ltr is not provided.
7. Exit & floors signage's is not provided at strategic location in the school building.
8. Standby power supply is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully

26/11/25

S.K. Dua
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi – 110085.