d11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/School/2026/SZ/ 53 Dated: 19/01/2026

To

The Principal,
Ruby Global School,
D–Block, Gurudwara Road,
Mohan Garden, New Delhi–110059

Sub: **Regarding issuance of Fire Safety Certificate in r/o Ruby Global School located at D–Block, Gurudwara Road, Mohan Garden, New Delhi–110059**

Sir,

This has reference e-mail dated 13/11/2025 received from Id. <rubyglobal18@gmail.com> along with attachment, on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 26/12/2025 in the presence of Ms. Amita Chopra (Coordinator). During course of inspection, the shortcomings observed are as below.

1. Hose-reel hose system not found provided, same shall be provided on each floor.
2. Terrace pump of 450 LPM capacity with 40 mtr head not found provided
3. Overhead water storage tank of 10,000 liters capacity exclusive for fire-fighting not provided.
4. Adequate exit signage at conspicuous locations shall be provided in the escape route.

In view of above, application for issuance of fire safety certificate cannot be considered at this stage. You are requested to rectify/submit compliance of the above-mentioned shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

16/1/26

(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi–110054.