C-125

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का अमृत महोत्सव

No. F6/DFS/MS/EH/NDZ/2026/120 Dated: - 11/02/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of FSC in r/o M/s Sagar Ratna (Sagar Ratna Restaurant Pvt Ltd), Ground Floor, 52, Janpath, Connaught Place, New Delhi - 110001.

Sir,

Please refer to online application No. 2026012000693 dated 20/01/2026, on the subject cited above. In this connection, it is to inform you that the said restaurant was inspected by the officers concerned of this department on **28/01/2026** in the presence of **Sh. Sunil, Manager** and following shortcomings were observed: -

1. Manually Operated Electronic Fire Alarm (MOEFA) provided but found non-functional.
2. Hose Reels were found removed.
3. Detectors were provided but found non-functional.
4. Exit Signages were found removed.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours faithfully,

10/2/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Manager, M/s Sagar Ratna (Sagar Ratna Restaurant Pvt Ltd), Ground Floor, 52, Janpath, Connaught Place, New Delhi - 110001.