G-133

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/NDZ/2026/ 491 Dated 25/05/2026

FIRE SAFETY CERTIFICATE

Certified that **M/s Sagar Ratna (Sagar Ratna Restaurant Pvt Ltd)** located at **Ground Floor, 52, Janpath, Connaught Place, New Delhi - 110001,** comprised of Ground + Inside Mezzanine + 03 Upper Floors but **Restaurant running at Ground only and Inside Mezzanine Floor – For Storage only** ***(as per affidavit dated 20.05.2026)*** was earlier issued **Fire Safety Certificate** by this department vide letter No. **F6/DFS/MS/EH/2022/312 dated 07/11/2022.** Now, the premises was re-inspected by the officer concerned of this department on **06/05/2026** in the presence of **Sh. Sunil, General Manager** and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 read with 35(6) of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class – **Assembly Occupancy for Restaurant at Ground Floor Only** with effect from 25/05/2026 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ...25/05/2026....at New Delhi by.

25/5/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service
O/C 25/5

Copy to: -

1. The Chairman, NDMC, Palika Kendra, New Delhi – 110001.: w.r.t. Online ID: - 2026042505748 dated 25/04/2026.
2. The Manager, M/s Sagar Ratna (Sagar Ratna Restaurant Pvt Ltd), Ground Floor, 52, Janpath, Connaught Place, New Delhi - 110001.

Conditions for the validity of Fire Safety Certificate

1. **This FSC is valid for Restaurant at Ground Floor only.**
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (l) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

N/30

INSPECTION REPORT

1.	Name & address of the building	M/s Sagar Ratna (Sagar Ratna Restaurant Pvt Ltd), Ground Floor, 52, Janpath, Connaught Place, New Delhi - 110001.		
2.	Type of occupancy	Assembly Occupancy - Eating House (Restaurant)		
3.	Building is Comprised of	Ground + Inside Mezzanine + 03 Upper Floors **Restaurant running at Ground only** **Inside Mezzanine Floor – For Storage only** ***(as per affidavit dated 20.05.2026)***		
4.	Type of case	**Renewal**		
5.	Details of previous FSC No.	F6/DFS/MS/EH/2022/312 dated 07/11/2022		
6.	Fire safety directives No.-	N/A		
7.	Date of inspection: -	06/05/2026		
8.	Name of the inspecting officer: -	Sh. Bhupender Prakash, ADO(CC)		
9.	Name & designation of officer From the building side: -	Sh. Sunil, General Manager		
10.	Year of construction: -	Old Heritage Building		
11.	Applicant's letter No: -	MCD Online ID 2026042505748 dated 25/04/2026		
S. No.	**Minimum Standards on fire Prevention and fire safety U/R**	**Requirement/ Existing fire safety arrangements**	**Provided at site**	**Remarks MR/NMR**
1.	**Access to Building**			
	• Road width	9.00 mtr.	16.00 mtr.	MR*
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	**Number, Width Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircase			
	• Upper floors (to Mezzanine Floor)	N/A	1.30 mtr. (Existing)	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.50 mtr.	02 X 1.50 mtr. & 01 X 1.00 mtr.	MR
3.	**Compartmentation**			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	**Smoke Management System**			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided Natural	MR
5.	**Fire Extinguishers**			
	• Total numbers	12 nos.	12 nos.	MR
	• Types	ABC/CO_2	ABC/CO_2	MR
	• ISI marking	Required	Provided	MR
6.	**First-Aid Hose Reel**			
	• Total number of each floor	02 nos.	02 nos.	MR

N|31

	• Length of hose reel hose	30 mtr.	30 mtr.		MR
	• Nozzle diameter	5mm	5mm		MR
7.	**Automatic Fire Detection & Alarming System.**				
	• Type of detectors	Required	Provided		MR
	• Location of main panel	Ground Floor	Provided		MR
	• Location of repeater panel	N/A	N/A		N/A
	• Alternate source of power	Required	Provided		MR
	• Hooter's Location	N/A	N/A		N/A
8.	**MOEFA**	Required	Provided		MR
9.	**Public Address System**	N/A	N/A		N/A
10.	**Automatic Sprinkler System**				
	• Basement	N/A	N/A		N/A
	• Ground Floor	N/A	Provided		N/A
	• Sprinkler above false ceiling	N/A	N/A		N/A
11.	**Internal Hydrants**				
	• Size of riser/down-comer	100 mm	Provided		MR
	• Number of hydrants per floor	01 no.	02 nos.		MR
	• Hose box per floor	01 no.	02 nos.		MR
12.	**Yard Hydrants**				
	• Total number of hydrants	N/A	N/A		N/A
	• Hose box	N/A	N/A		N/A
13.	**Pumping Arrangement**				
	Ground level				
	• Discharge of main pump	N/A	N/A		N/A
	• Head of main pump	N/A	N/A		N/A
	• Number of main pumps	N/A	N/A		N/A
	• Jockey pump out put	N/A	N/A		N/A
	• Jockey pump head	N/A	N/A		N/A
	• Stand by pump output	N/A	N/A		N/A
	• Stand by pump head	N/A	N/A		N/A
	• Auto starting/Manual stopping	N/A	N/A		N/A
	Terrace level				
	• Discharge of pump	450 LPM	450 LPM		MR
	• Head of pump	30 mtr.	30 mtr.		MR
	• Power supply	Required	Provided		MR
	• Auto starting of pump	Required	Provided		MR
14.	**Captive Water Storage for Fire Fighting**				
	• Underground tank capacity	N/A	N/A		N/A
	• Draw-off connection	N/A	N/A		N/A
	• Fire service inlet	N/A	N/A		N/A
	• Access to tank	Required	Provided		MR
	• Overhead tank capacity	10,000 Ltrs	10,000 Ltrs		MR
15.	**Exit Signage.**	Required	Provided		MR
16.	**Provision of Lifts.**				
	• Pressurization of lift shaft	N/A	N/A		N/A
	• Pressurization of lift lobby	N/A	N/A		N/A
	• Communication in lift car	N/A	N/A		N/A
	• Fireman's switch	N/A	N/A		N/A
	• Lift signage	N/A	N/A		N/A
17.	**Stand by Power Supply**	Required	Provided		MR

18.	**Refuge Area**			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	**Fire Control Room**			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	**Special Fire Protection System for Protection of special Risk, if any:** ABC & CO_2			MR

*PNF – Provided but Non-Functional, *MR – Meeting Requirement, *NMR – Not Meeting Requirement

The fire protection system provided in the building were randomly checked and found functional at the time of inspection. Further, shortcomings issued vide letter No. F6/DFS/MS/EH/NDZ/2026/120 dated 11.02.2026 found complied.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, if approved, we may renew the FSC issued vide letter No. F6/DFS/MS/EH/2022/312 dated 07/11/2022 under Rule 35(6) of Delhi Fire Service Rules, 2010. The last date for deemed approval is **24/05/2026**.

Accordingly, **DFA** is prepared and put up for perusal and signature please.

BPrakash 20/5/2026
Bhupender Prakash
ADO (CC)

DO (CD) 20/05/26

CFO (NDZ)

20/5/26

Principal Director

CFO to Director

21/05/26

CFO (NDZ)

25/5/26

ADO/CC – on file ADO (HQ)

F.T. letter is put up for signature, Please.

25/05/2026

C.F.O. (NDZ)

25/5/26

Uploaded 26/5/26