C/38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/Institutional/SZ/2025/ 512 Dated: 24/10/2025

To,

Mr. Rajat Sikka,
SAMA Hospital,
Plot No. E-522, Greater Kailash Part- II,
Delhi - 110048.

Subject: - Regarding grant of Fire Safety Certificate in r/o SAMA Hospital located at Plot No. E-522, Greater Kailash Part- II, Delhi - 110048.

Sir,

This has a reference to your outdoor diary No. 5497 dated 01/09/2025, on the subject cited above. In this connection, it is to inform you that premise was inspected by the officer concerned of this department on 16/10/2025 in the presence of Mr. Avnish Kumar and observed that building comprised of Basement, Stilt, Ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. The staircase is not segregated at stilt floor.
2. The exit door width of patient room is 1.10 mtr against the required width of 1.25 mtrs each.
3. Fire check door not provided in staircase and lift lobbies.
4. Smoke management systems not provided in the basement and upper floors.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

Anilalk 24/10/25

(A.K. Malik)
Dy. Chief Fire Officer
o/c Delhi Fire Service