C177

आज़ादी का अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/school/SZ/2026/ 895 Dated: /25/09 /2026

To,

Sh. Hoshiyar Singh (Manager),
Sant Nagpal Public School,
Gole Building Chhatarpur Mandir Complex,
New Delhi-110074.

Sub: Regarding issuance of FSC from fire safety point of view in r/o. M/s Sant Nagpal Public School, located at Gole Building Chhatarpur Mandir Complex, New Delhi-110074. (C& D block).

Sir,

Please refer to your letter No. SNPS/2026-27/57 dated- 09/06/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 07/09/2026 in the presence of Sh. Hoshiyar Singh (Manager) to see the functioning of fire safety arrangements/equipment's provided in the building. During inspection, the following shortcomings were observed.

1. First Hose reels are provided but non-functional.
2. Terrace level fire pump 450 LPM is provided but not on auto mode.
3. Exit signages are not provided.
4. Building plan as submitted is not legible. Complete set of building plan including section is also required to be submitted.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is cannot considered at this stage & rejected.

Yours faithfully,

24/9/26

(A.K. Malik)
Chief Fire Officer

Copy To: -

1. The Director, Directorate of Education, Old Sectt. Delhi-110054.