C-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/School/2025/SZ/843 Dated: 27 / 11 /2025

To

The Principal/HOS,
Sarvodaya Bal Vidyalaya, Block-A,
Vikas Puri, Delhi–110018

Sub: Renewal of Fire Safety Certificate in r/o Sarvodaya Bal Vidyalaya (New Block), Block-A, Vikas Puri, Delhi–110018 (School ID: 1618002)

Sir,

This has reference to your letter No. 303/SBV A-Blk/Admin/2025/Land & Estate/1078 Dated 16/09/2025, received in this department vide outdoor diary No. 6109 dated 18/09/2025. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 10/11/2025 in the presence of Sh. Prahlad Singh (Estate Manager). During course of inspection, the shortcomings observed are as below.

1. Hose-reel hose found provided but non-functional.
2. Terrace level fire pump found non-functional.
3. Exit signage found removed at some places.

In view of the above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify/submit compliance of the above-mentioned shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

24/11/25

(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi–110054.