GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6 /DFS/MS/School/SZ/2025/785 Dated: 23/10/2025

To,

The Vice Principal,
Sarvodaya Co-Ed Vidyalaya
Hari Nagar, Ashram,
New Delhi – 110014.

Sub: - Regarding grant of Fire Safety Certificate in r/o Sarvodaya Co-Ed Vidyalaya located at Hari Nagar, Ashram, New Delhi – 110014.

Sir,

This has a reference to your Outdoor Diary no. 5745 dated 09.09.2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 09/10/2025 in the presence of Mr. Tara Chand (Estate Manager) and observed that building comprised of Two Blocks (Ground plus three upper floors each) and following shortcomings were observed during time of inspection:

1. Fire Extinguisher found empty.
2. Hose reel hose provided but nonfunctional.
3. Fire pump of 450 LPM provided but nonfunctional.
4. Exit Signage's found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

23/10/25

(A.K. Malik)
Dy. Chief Fire Officer
o/c Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.
2. The Principal, Sarvodaya Co-Ed Vidyalaya located at Hari Nagar, Ashram, New Delhi – 110014.
3. The Assistant Engineer (E), PWD Sub-Division M1-PWD, Hauz Khas, New Delhi – 110016.