GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/SZ/2025/ 804 Dated: 12/11 /2025

To,

The principal,
Sarvodaya Kanya Vidyalaya (Morning Shift)
Chander Shekhar Azad Govt. Boys. Sr. Sec. School (Evening Shift),
New Friends Colony, New Delhi-110025.

Subject: - Regarding grant of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya (Morning Shift)/ Chander Shekhar Azad Govt. Boys. Sr. Sec. School (Evening Shift) located at New Friends Colony, New Delhi - 110025

Sir,

This has a reference to your Outdoor Dairy No. 7042 dated 14/10/2025 on the subject cited above. In this connection, it is to inform you that school was inspected by the officer concerned of this department on 28/10/2025 in the presence of Mrs. Indira Sagar (HOS) and observed that school building comprised of Two block A block – Ground + 3 upper floors & B block - 3 upper floors.

Following shortcomings were observed during time of inspection:

1. Hose reel provided but found not functional each block.
2. Fire pump of capacity 450 LPM provided but not functional each block.

In view of above shortcomings, the application for **issuance of Fire Safety Certificate is rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

You're faithfully,

11/11/25
(A.K.Malik)
Dy. Chief Fire Officer
Delhi Fire Service
O/C (W)

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.