C-20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/School/2025/SZ/859 Dated: 13/12/2025

To

The Principal/HOS,
Sarvodaya Kanya Vidyalaya,
District Centre, Vikas Puri,
New Delhi–110018

Sub: Renewal of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya, District Centre, Vikas Puri, New Delhi–110018 (School ID: 1514017)

Sir,

This has reference to your letter No. SKV/DC/VP/2025/462 dated 15/09/2025, received in this department through outdoor diary No. 6479 dated 26/09/2025. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 20/11/2025 in the presence of Sh. Pawan Kumar (Estate Manager). During course of inspection, the shortcomings observed are as below.

1. Hose-reel hose found provided but non-functional.
2. Terrace level fire pump found provided but non-functional.
3. Exit signage found removed at some locations.

In view of the above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

11/12/25

(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi–110054.