C187

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/WZ/2026/49

Dated: 14./01./2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Satyam Guest House, 06, Bhera Enclave, Paschim Vihar, New Delhi - 110087.

Sir,

This has reference to online application received through MCD online portal vide ID No. 2025021101718 dated 16/12/2025 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on **24/12/2025** in the presence of **Sh. Subhash Bajaj (Owner)** and following shortcomings were observed: -

1. Fire Check doors were found removed at some places.
2. Carbon Monoxide detectors were not provided.
3. Manual Operated Electronic Fire Alarm (MOEFA) provided but found non-functional.
4. Automatic operation of Fire pump found removed.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

14/01/26

(S. K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service

01CBB

Copy to: -

1. The Manager, M/s Satyam Guest House, 06, Bhera Enclave, Paschim Vihar, New Delhi - 110087.