GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No:F.6/DFS/MS/GH/2026/WZ/308 Dated: 10/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
S.P.M. Civic Centre, J.L. Nehru Marg,
New Delhi 110002.

Sub: -Regarding renewal of Fire Safety Certificate in r/o M/s Satyam Guest House located at 06, Bhera Enclave, Paschim Vihar, New Delhi-110087.

Sir,

This has reference to online application received through MCD portal vide ID- 2026031302824 on the subject cited above. In this connection, it is to inform you that the above said residential building was re-inspected by officer concerned of this department on 24/03/2026 to see the compliance of requisite fire safety measures. Sh. Subhash was present at the time of inspection. Following shortcoming were observed at the time of inspection.

1. Fire Check door found removed at some places.
2. Carbon monoxide detectors were not provided.
3. MOEFA found provided but not functional.
4. Terrace level Pump not found in auto mode.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

09/04/26

S.K. Dua
Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Copy to:-

1. M/s Satyam Guest House located at 06, Bhera Enclave, Paschim Vihar, New Delhi – 110087.
2. MCD Portal ID No. 2026031302824.