c/36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001

No.F.6/DFS/MS/SZ/2025/School/883 Dated: 16/12/2025

To,

Mr. Barun Kumar Singh (Principal),
S.D.M.C Primary Model School,
Raj Nagar-Extension – II, Palam Colony,
New Delhi – 110077.

Subject: Renewal of Fire Safety Certificate iro S.D.M.C Primary Model School, Located at Raj Nagar-Extension – II, Palam Colony, New Delhi – 110077.

Sir,

Please refer to your letter no Form J Dated – 13/11/2025 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 01/12/2025 for fire safety point of view.

The following shortcomings ware observed during the time of inspection:-

1. Hose reel hose found non functional
2. Terrace pump found nonfunctional.
3. Overhead water storage tank for fire fighting 8000 litres provided in place of required 10000 litres. All the fire fighting tanks are found empty.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

15/12/25

(A.K. MALIK)
Dy. Chief Fire Officer (S/)
Delhi Fire Service

Copy to; - Directorate of Education Old Secretariat Delhi – 110054