GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-6

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2025/ 863 Dated:- 03/12/2025

To,

The Manager,
Shanti Gyan Public School,
H.No. 319, Kh. No. 96/1, Village Holambi Kalan,
Delhi-110082.

Subj.:-Regarding issuance of Fire Safety Certificate in respect of Shanti Gyan Public School, located at H. No. 319, Khasra No. 96/1, Village Holambi Kalan, Delhi-110082 .

Sir,

Please refer to your email dated 17/09/2025 on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by the officer concerned of this department on 10/11/2025 in the presence of Sh. Balraj (Manager). During inspection, it has been observed that the school building is comprised of Ground + 03 Upper Floor. However, the following shortcoming has been observed:-

1. 02 nos. staircases are provided having width 1.5 m (Ground to Terrace) & 0.9 m (Ground to 2nd floor) against required of 1.5 m each & all staircase should leads to terrace.
2. 01 no. First Aid Hose Reel is provided but found non-functional against requirement of 02 nos.
3. At Terrace, Fire pump of 450 lpm capacity is not provided.
4. Exit signages are not provided.

In view of the above shortcomings, the application for issuance of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action. The occupancy of the building/premises in absence of requisite fire safety certificate arrangements shall be at the risk and liability of owner/occupier. Statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,

02/12/25

S.K. Dua
Dy. Chief Fire Officer (WZ)

01/12/25

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.