GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 576 Dated: -19/06/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Shiv Dev International, 8518-22, A. K. Road, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026060307919 dated 03/06/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 12/06/2026 in the presence of Sh. Ajay Kumar, Manager and following shortcomings were observed: -

1. Fire Check doors found removed.
2. Automatic operation of Fire pump found removed.
3. Domestic connection provided in Overhead Water storage tank is not permissible.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

19/6/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Manager, M/s Shiv Dev International, 8518-22, A. K. Road, Paharganj, New Delhi - 110055.