GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/BP/2026/ 477 Dated: 06/11/2026

To

The Chief Architect,
NDMC Head Office,
Palika Kendra, Parliament Street,
New Delhi-110001

Sub:- **Rejection** of building plans from fire safety point of view in r/o Shiv Mandir at Chankya Puri, Kautilya Marg, Delhi-110021.

Sir,

With reference to file No. PRJ/0075/2026 dated 27.10.2026 on the subject cited above; it is informed that the referred building plans in respect of Shiv Mandir at Chankya Puri, Kautilya Marg, Delhi-110021 were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcomings were observed:-

1. Fire prevention & fire safety measures are not proposed as per UBBL-2016.
2. Exits shall not pass through occupied area as per UBBL-2016.
3. The staircases shall strictly be provided as per UBBL-2016 with proper width 2 m, tread 30 cm & riser not more than 15 cm.
4. Kitchen is not segregated as per UBBL-2016.

In view of the above, the building plans are **rejected** with a request to resubmit plans after rectification of above shortcomings for further consideration in the matter.

Yours faithfully,

(A.K. Malik)
Chief Fire Officer