c/45

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/School/2025/SZ/ 760 Dated: 03/10/2025

To

The Principal/Manager,
Shiv Vani Model Sr. Sec. School,
Mahavir Enclave, Palam-Dabri Road,
Dwarka, New Delhi–110045

Sub: Renewal of Fire Safety Certificate in r/o Shiv Vani Model Senior Secondary School at Mahavir Enclave, Palam-Dabri Road, Dwarka, New Delhi–110045

Sir,

This is with reference to your letter No. Nil dated 22.07.2025, received in this department through outdoor diary No. 4358 dated 31/07/2025. In this connection, it is to inform you that the premise was inspected by the concerned officer of this department on 19/09/2025 in the presence of Sh. Atul Arora (Estate Manager) and observed addition/alteration in the building as auditorium/multi-purpose hall found constructed between 2nd and 3rd floor, also lift has been installed. Thus, the shortcomings observed is as below.

1. Hose-reel hose found non-functional.
2. Terrace level fire pump found non-functional.
3. Exit signage found removed at some places.
4. Temporary structure found erected on terrace floor being used by staff; using LPG cylinder.
5. Approval of addition/alteration with regard to construction of auditorium/multi-purpose between 2nd and 3rd floor hall and installation of lift be provided.

In view of the above, renewal of fire safety certificate cannot be considered at this stage. You are requested to submit compliance of the above-mentioned shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

29/9/2025

(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi–110054.