C/13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/EH/NDZ/2025/ 489 Dated: 23/12/2025

To,

Sh. Suresh Chandra,
M/s Shree Hari Sharanam Restaurant
Prop. No. 208 Street Katra Bariyan, First Floor,
Fateh Puri, Delhi- 110006

Subject:-Regarding issuance of Fire Safety Certificate in r/o M/s Shree Hari Sharanam Restaurant located at Prop. No. 208 Street Katra Bariyan, First Floor, Fateh Puri, Delhi- 110006

Sir,

This has reference to your MCD online application ID No. **2025120315354** dated 03/12/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 13/12/2025 in presence of Sh. Vijay Sharma. The premises is comprised of Ground plus three upper floors but restaurant is running at first floor only. The following shortcoming were observed during the time of inspection.

1. Two staircases of width 1.42 meter & 0.9 meter are provided against the requirement of two staircases of width 1.50 meter each.
2. The Fire Check Doors shall be required in the kitchen.
3. First aid hose reel is provided but not functional.
4. MOEFA is not provided.
5. Down Comer is provided but not functional.
6. Terrace pump capacity 450 lpm 40 meters head provided but not functional.
7. An overhead tank capacity 4,000 liters provided against the requirement of 20,000 liters.
8. Exit Signages are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

22/12/25

(Dr. S. K. TOMAR)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

o/c R.

MCD online ID :- **2025120315354**