**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI–110001**

No. F.6/DFS/MS/EH/NDZ/2026/ 147

Dated: 18/02/2026

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, New Delhi - 110002.

**Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o M/s Shri Hari Sharnam Restaurant situated at Prop. No. 208, First Floor, Katra Bariyan, Fateh Puri, Chandni Chowk, Delhi - 110006.**

Sir,

This has reference to MCD portal online application Id No.2026013001048 dated 30.01.2026 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on dated 10.02.2026 and observed that the shortcomings intimated vide letter of even No.F.6/DFS/MS/EH/NDZ/2025/489 dated 23.12.2025 (copy enclosed) have not been complied yet.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building /premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

Encl: As above.

17/2/26

**(Dr. S. K. Tomar)**
Dy. Chief Fire Officer
Delhi Fire Service

**Copy to:-**

The Manager,
M/s Shri Hari Sharnam Restaurant situated at Prop. No. 208, First Floor, Katra Bariyan, Fateh Puri, Chandni Chowk, Delhi - 110006.

C/13

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**
**NEW DELHI- 110 001**

No.F.6/DFS/MS/EH/NDZ/2025/ 489

Dated: 23/12/2025

To,

Sh. Suresh Chandra,
M/s Shree Hari Sharanam Restaurant
Prop. No. 208 Street Katra Bariyan, First Floor,
Fateh Puri, Delhi- 110006

**Subject:-Regarding issuance of Fire Safety Certificate in r/o M/s Shree Hari Sharanam Restaurant located at Prop. No. 208 Street Katra Bariyan, First Floor, Fateh Puri, Delhi- 110006**

Sir,

This has reference to your MCD online application ID No. **2025120315354** dated 03/12/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 13/12/2025 in presence of Sh. Vijay Sharma. The premises is comprised of Ground plus three upper floors but restaurant is running at first floor only. The following shortcoming were observed during the time of inspection.

1. Two staircases of width 1.42 meter & 0.9 meter are provided against the requirement of two staircases of width 1.50 meter each.
2. The Fire Check Doors shall be required in the kitchen.
3. First aid hose reel is provided but not functional.
4. MOEFA is not provided.
5. Down Comer is provided but not functional.
6. Terrace pump capacity 450 lpm 40 meters head provided but not functional.
7. An overhead tank capacity 4,000 liters provided against the requirement of 20,000 liters.
8. Exit Signages are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

22/12/25

**(Dr. S. K. TOMAR)**
**DY. CHIEF FIRE OFFICER**
**DELHI FIRE SERVICE**

o/c R.

MCD online ID :- **2025120315354**