GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-6

No.F6/DFS/MS/School/WZ/2025/832 Dated: 24/11/2025

To

The Executive Engineer (Bldg.) H.Q,
Municipal Corporation of Delhi,
8 th Floor, Minto Road, New Delhi

Ref: JSI against ID no. 10121219.

Sub: Regarding issuance of Fire Safety Certificate in r/o Shri Ram Wonder Years Nursery School (Operating under Jeewan Charitable Society) located Block-KU, Pitampura, Delhi-34.

Sir,

In connection to the above referred request ID, the site was visited by a team of officers from this department on 13.11.2025 alongwith Sh. Rahul Kumar Jayshwal, JE (Bldg.), Sh. S.P. Dabas, AE (Bldg.) from MCD in the presence of Sh. Suresh Chand Jain (President) for Joint Site Inspection and it was observed that the school is running on Ground + 01 upper floor of the building is comprised of Ground + 02 upper floor & 2nd floor used as a Pediatrics OPD. During the inspection following shortcomings were observed:-

1. Alternate exit shall not pass through the occupied area at ground floor.
2. Alternate exit door not provided to the alternate staircase at 1st floor.
3. Five nos. of Fire Extinguishers has not been provided.
4. Corridor width of 1.50 meters has not been provided.
5. Both staircases shall lead upto the terrace.
6. First aid hose reels have not been provided at each floor.
7. Terrace Fire pump of 450 LPM with head 40 m has not been provided.
8. Overhand tank capacity of 10,000 liters for firefighting has not been provided.
9. Exit signage has not been provided.
10. Overhead clearance of at least 5 meters shall be provided at the main entrance of the building.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

24/11/25

(S. K. Dua)
Dy. Chief Fire Officer (WZ)

o/c 20/12/25

Copy to:
1. The President, Shree ram Wonder Years Nursery School (operating under Jeewan charitable Society) located at Block-KU, Pitampura, Delhi – 34.