C/69 C-89

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI – 110001

No. F6/DFS/MS/GH/NDZ/2026/307 Dated: 10 / 04 /2026

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, New Delhi - 110001.

Sub: Regarding renewal of Fire Safety Certificate in respect of **M/s Shyama Inn** located at **5050, First & Second Floor, Netaji Subhash Marg, Daryaganj, Delhi - 110002.**

Sir,

This has reference to MCD online application ID. No. 2026031202786 dated 12.03.2026on the subject cited above. In this connection, it is to inform you that the building/premises was re-inspected by the officer concerned from this department on 25.03.2026 in the presence of Manager and it was observed that building is comprised of Ground + Mezzanine + 03 upper floors. During inspection, following shortcomings were observed:

1. Fire check doors which are required as per gazette notification dated 27.05.2019, not provided.
2. First aid hose reel found non functional.
3. Terrace fire pump provided but not functional and not on auto start mode.
4. Occupancy above second floor (including mezzanine) is not permitted as per gazette notification dated 27.05.2019.

Keeping in view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

10/4/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-.
The Licensee,
M/s Shyama Inn, 5050, First & Second Floor, NetajiSubhashMarg, Daryaganj, Delhi -110002.