C/64

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/School/SZ/2026/ 174 Dated: 17/11/2026

FIRE SAFETY CERTIFICATE (FSC)

Certified that the M/s South Delhi Public School located at D- Block, Defence Colony, New Delhi-24, comprised of Ground + 02 upper floors was granted Fire Safety Certificate (FSC) by this department vide letter no.- F6/DFS/MS/School/2018/SZ/2260 dated 08.10.2018. The school building was re-inspected by officer concerned of this department on 03/11/2026 in the presence of Mr. B.S. Rana (Admin Officer) and building/premises has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and the building (Ground + 02 upper floors) is fit for occupancy of Group B" Educational Building" with effect from 17/11/2026... renewed for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on..17/11/2026.....at New Delhi by

17/11/26

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

17/11/26

Copy to:-.

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, South Delhi Public School located at D- Block, Defence Colony, New Delhi-24.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/24

INSPECTION REPORT					
1	Name & address of the building		**South Delhi Public School located at D- Block, Defence Colony, New Delhi-24.**		
2	Building is comprised of		**Ground + 02 upper floors**		
3	Type of occupancy		Group B –Educational Building		
4	Type of case		Renewal/Addition at 2nd floor.		
5	Details of previous FSC		F6/DFS/MS/School/2018/SZ/2260 dated 08.10.2018		
6	Fire safety directive letter no.		F6/DFS/MS/BP/2022/School/148 dated 31.03.2022		
7	Date of inspection		03/11/2026		
8	Name of the inspecting officers		Rajesh Kumar Shukla, ADO (Jangpura)		
9	Name of the designation of officer from the building side		Mr. B.S. Rana (Admin Officer)		
10	Year of construction		1978 & 2022		
11	Applicant's letter no.		DFS portal online application no. 52026080804956		
S.No	**Minimum standard of fire prevention and fire safety U/R 33**		**Requirements as per directive dated 31.03.2022**	**Provided at site**	**Remarks MR/NMR**
1	**Access to Building:**				
	A	Road width	6.0 m	12 m	MR
	B	Gate width	4.5 m	Provided	MR
	C	Width of internal road	NA	NA	NA
2	**Number, Width, Type and Arrangement of Exits:**				
	A	Number of staircases			
	a	Upper floor	3 Nos.	3 Nos.	MR
	b	Basement	NA	NA	NA
	B	Width of staircases			
	a	Upper floor	1.5 m each	Provided	MR
	b	Basement	NA	NA	NA
	C	Protection of exits	NA	NA	NA
	a	Fire check door	NA	NA	NA
	b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	03 Nos.	Provided	MR
	E	Width of corridor	1.5 m	Provided	MR
	F	Door size	1.0 m for old class rooms & 1.20 m of 04 new class rooms	1.0 m for old class rooms & 1.20 m of 04 new class rooms	MR
3	**Compartmentation:**				
	A	Fire check door	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft door	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	**Smoke Management System:**				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
5.	**Fire Extinguisher:**				
	A	Total numbers	12 nos.	32 nos.	MR
	B	Types	CO_2 & ABC	CO_2 & ABC	MR
	C	ISI marking	ISI Marked	Provided	MR
6	**First-Aid-Hose Reel:**				
	A	Total numbers of each floor	2 nos.	3 nos.	MR
	B	Length of hose reel hose	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	5 mm	5 mm	MR

N/25

7	**Automatic Fire Detection and Alarming System:**				
	A	Type of detectors	NA	NA	NA
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters	NA	NA	NA
8	**MOEFA:**		NA	NA	NA
9	**Public Address System:**		NA	Provided	NA
10	**Automatic Sprinkler System:**				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	**Internal Hydrants:**				
	A	Size of riser/**down-comer**	NA	100 mm	NA
	B	Number of hydrants per floor	NA	03 nos.	NA
	C	Hose box	NA	03 nos.	NA
12	**Yard Hydrants:**				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	**Pumping Arrangements:**				
A	**Ground level**				
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
B	**Terrace Level**				
	a)	Discharge of pump	450 LPM	900 LPM	MR
	b)	Head of the pump	40 m	40 m	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR
14	**Captive Water Storage for Fire Fighting:**				
	a	Underground tank capacity	NA	NA	NA
	b	Draw-off connection	NA	NA	NA
	c	Fire service inlet	NA	NA	NA
	d	Access to tank	NA	NA	NA
	e	Overhead tank capacity	10,000 ltrs	Provided	MR
15	**Exit Signage:**		Required	Provided	MR
16	**Provision of Lifts:** No lift installed in the building				
	a	Pressurization of lift shaft	NA	NA	NA
	b	Pressurization of lift lobby	NA	NA	NA
	c	Communication in lift car	NA	NA	NA
	d	Firemen's grounding switch	NA	NA	NA
	e	Lift signage	NA	NA	NA
17	**Standby Power Supply:**		NA	NA	NA
18	**Refuge Area:**				
	a	Total area	NA	NA	NA
	b	Location	NA	NA	NA

19	**Fire Control Room:**				
	a	Detector system panel	NA	NA	NA
	b	Flow switch panel	NA	NA	NA
	c	PA system panel	NA	NA	NA
	d	Battery backup	NA	NA	NA
	e	Building floor plans	NA	NA	NA
20	**Special Fire Protection systems for protection of special Risks, if any:**		NA		NA

LEGENDS: Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested checked and found properly functional at the time of inspection.

In view of the compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/School/2018/SZ/2260 dated 08.10.2018 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

03/11/26

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (Jangpura)

DO (SD)

4/11/26
Ravinder Singh

4/11/26
A.K. MALIK

9/11/26

Recieved on 12/11/26

12/11/26
A.K. MALIK

12/11/26
Ravinder Singh

Ref. Prepage

FI is put for signatures pls

17/11/26

CRO (EZ)

17/11/26

A.K. MALIK

M.S. cell