GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

Application ID. 52026072704711

Dated: 17-11-2026

SHORTCOMING(S)

With reference to your application ID **52026072704711** dated **17-11-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Surya CGHS Ltd.** at **Plot No. 14, Sector- 06, Dwarka, New Delhi-110075** from fire safety point of view in presence of **Sh. Hari Om Garg** on dated **14/10/2026** During the course of inspection following observations were made:-

1. First aid hose reels provided but found not functional.
2. Internal Hydrant and Yard Hydrant provided but found not functional.
3. Terrace level fire pump provided but found not functional.
4. Exit Sign's found removed at some places.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-
1. HARI OM GARG , Surya Apartment, Plot no 14, Sector 6, Dwarka, Delhi, 110075
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.