C/71

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/Hosp./NDZ/2026/2000 Dated: 27/05/2026

To,

The Medical Superintend (Nursing Home Cell)
GNCTD, Directorate General of Health Services,
3rd Floor, Delhi Government Dispensary building,
S -1, School block, Shakarpur, Delhi – 110092.

Sub: - Regarding Issuance of Fire Safety Certificate in r/o Surya Hospital, 383/11C & 383/8- B, East Azad Nagar, Delhi – 110051.

Sir,

This has reference to your letter No. F.23/423/Misc./West/DGHS/NHC/2025/1632 - 33 dated 10/04/2026 and F.23/423/Misc./West/DGHS/NHC/2025/1684-85 dated 16/04/2026 received through in this office vide dairy No. 311 dated 10/04/2026 and 513 dated 17/04/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 14/05/2026 in presence of Dr. Harsh and observed that the shortcomings as communicated earlier vide letter No.F.6/DFS/MS/Hosp./2025/NDZ/625 dated 17/12/2025 (copy enclosed) have not been completed yet.

In view of the above for **Fire Safety Certificate cannot be considered at this stage.** The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

27/5/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service
O/C

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/Hospital/2025/NDZ/ 625

Dated: 17/12/2025

To,

Dr. Shalini Tiwari (Medical Superintendent)
Surya Hospital (Prop. Misra Hospital & Nursing Hospital Pvt. Ltd.)
383/11C & 383/8 B, East Azad Nagar, Krishana Nagar,
Delhi-110051

Subject: -Regarding issuance of Fire Safety Certificate in r/o Surya Hospital (Prop. Misra Hospital & Nursing Hospital Pvt. Ltd.) at Prop. No. 383/11C & 383/8 B, East Azad Nagar, Krishana Nagar Delhi-110051.

Sir,

With reference to your letter outdoor Diary No. 5636 dt 04/09/2025 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 15/11/2025 & 01/12/2025 in the presence of Dr. Shalini Tiwari (Medical Superintendent), The hospital building comprised of basement, ground plus three upper floors & ground plus three upper floors (two separate building blocks). During the course of inspection following observations were made: -

1. An additional staircase of width 02 meter shall be required in second block.
2. Fire check door not provided in entire buildings.
3. Basement segregate shall be required.
4. Smoke management system not provided in the entire building.
5. First Aid hose reels Provided but not functional.
6. Automatic Fire Detection and Alarm system not provided.
7. MOEFA not provided.
8. Automatic sprinkler system not provided.
9. Ground level Main pump & Standby pump capacity 1620 lpm head 70 meter and 180 lpm jockey pump head 70 meter not provided.
10. Draw-off connection & Fire service inlet not provided.
11. An overhead tank capacity 5,000 liters provided against the requirement 10,000 liters shall be required.
12. Firemen's ground switch not provided.
13. As per application dated 04/09/2025 it was stated that the building no. 383/8-B. East Azad Nagar, Krishana Nagar, Delhi-110051, comprised of G+2 upper floors. However, during the inspection it was observed that the building is comprise of G+3 floors. Therefore, you are requested to submit the sanction building plan.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangement s shall be at the risk and liability of the owner/occupier, The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

17/12/25

(Dr. S. K. TOMAR)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

O/C

Copy to:-

1. The Medical Superintendent (Nursing Home),
   Directorate General of Health Services, (Nursing Home Cell), 3rd floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi-110092 Delhi-110032