GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2026/ 514 Dated: 25/05/2026

To,

The Principal,
Swami Sivananda Memorial Primary School
& Swami sivananda Memorial Secondary School,
31, East Avenue Road, East Punjabi Bagh,
New Delhi-110026.

Subject: - Regarding issuance of Fire Safety Certificate in r/o Swami Sivananda Memorial Primary School & Swami sivananda Memorial Secondary School, located at 31, East Avenue Road, East Punjabi Bagh, New Delhi-110026.

Sir,

This has a reference to your application received through Email dated 25/04/2026, on the subject cited above. In this connection, this is to inform you that the above-mentioned school was visited by the officer concerned of this department on dated 14/05/2026 in the presence of Mr. Parmod Kumar (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation: -

1. First Aid Hose reels provided but found non functional.
2. Terrace level Fire Pump capacity of 450LPM provided but found non functional.
3. Over head water storage tank capacity of 10,000 ltrs found empty.
4. Exit Signage's re not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management.

Yours faithfully,

25/05/26

(S. K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to :

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.