C/61

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/EH/2026/SZ/ 725 Dated: 10/09/2026

FIRE SAFETY CERTIFICATE

Certified that the **M/s Symposium Restaurant** located at Unit No. 101, 1st floor of City Centre Mall, Plot No. 05, Sec. 12, Dwarka, New Delhi- 110075, running at first floor of City Centre Mall building comprised of 02 basement, ground plus 05 upper floors,was issued FSC by this department vide letter No. F.6/DFS/MS/SZ/2023/129 dated 21.04.2023. The eating house building was re-inspected by the officer concerned of this department on dated 14.08.2026 in the presence of the Manager, and found that the restaurant have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant building/premises (**Restaurant running at first floor only**) is fit for occupancy class Group "D" Assembly Building" w.e.f. 10/09/2026 for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 10/09/2026 at New Delhi.s

9/9/26

(A.K. Malik)
Chief Fire Officer
South Zone

Online application Id 2026073110219 dated 03.08.2026.

Copy to: - The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi. : - **to inform about use of basement and a request to ensure the occupancy as detailed above and deviation, if any.**

Conditions for validity of Fire Safety Certificate:-

1. **The FSC issued only for eating house/ restaurant running at first floor only.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The basement shall be used as per the building bye laws.
8. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/14

INSPECTION REPORT

1. Name & address of the building : Symposium located at Unit No. 101, first floor of City Centre Mall Plot No. 5, Sector- 12, Dwarka, New Delhi- 110075.
1. Building is comprised of : **Restaurant running at First floor only in City Centre Mall.**
2. Type of Occupancy : Group D (Assembly)
3. Type of Case : Renewal (Eating House)
4. Details of Previous NOC : F.6/DFS/MS/SZ/2023/129 dated 21.04.2023
5. Fire Safety directives letter No : As per NBC of India part IV (2005)
6. Date of inspection : 14.08.2026
7. Name of Inspecting Officers : R.K. Yadav, ADO (DWK)
8. Name and designation of officers From the building side : Manager
9. Year of Construction : 2015
10. Applicant's letter No. : MHA Portal ID 2026073110219 dated 03.08.2026

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 21.04.2023	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	6.0 m	Provided	MR
	• Gate width	N/A	5.0 m	N/A
	• Width of internal road	N/A	6.0 m	N/A
2.	**Number, Width, Type & Arrangement of Exits**		**(common with mall)**	
	a. Number of staircases	**Restaurant running at first floor only**		
	• Upper Floors	02 nos. (for restaurant)	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	1.5 m	Proivded	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
		1.5 m each (02 nos.)	2.0 & 1.5 m	MR
3.	**Compartmentation**			
	• Fire check door	N/A	Provided	N/A
	• Sealing of electrical shafts	N/A	Provided	N/A
	• Fire Rating of shaft door	N/A	Provided	N/A
	• Water Curtain	N/A	Provided	N/A
	• Fire Dampers	N/A	Provided	N/A
4.	**Smoke Management System**			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 ACPH	Provided	MR
5.	**Fire Extinguishers-98**			
	• Total numbers in restaurant	06 no.'s	Provided	M/R
	• Types	ABC/CO_2	ABC- 03& Co2- 03	M/R
	• IS marking	ISI marked	Provided	M/R
6.	**First-Aid Hose Reels**	**Provided & Maintain by Mall**		
	• Total numbers at each floor	01 no's for restaurant	Provided	M/R
	• Length of hose reel hose	36 m	Provided	M/R
	• Nozzle diameter	5 mm	Provided	M/R

N/15

7.	**Automatic fire detection and alarming system in restaurant**			
	• Type of detectors Smoke/Heat	Smoke/Heat	Provided	MR
	• Location of Main Panel	Required	Provided at GF	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	**MOEFA**	Required	Provided	MR
9.	**Public Address System**	N/A	Provided by Mall	N/A
10.	**Automatic Sprinkler System**	**Common with Mall**		
	• Basement	N/A	Provided	N/A
	• Upper floors	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	Provided	N/A
11.	**Internal Hydrants**	**Provided & Maintain by Mall**		
	• Size of riser/down-comer	100 mm	Provided	M/R
	• Number of hydrants	01 no's for restaurant	Provided	M/R
	• Hose Box	Required	Provided	M/R
12.	**Yard Hydrants**	**Provided & Maintain by Mall**		
	• Total number of hydrants	N/A	Provided	N/A
	• Hose Box	N/A	Provided	N/A
13.	**Pumping Arrangements**	**Provided & Maintain by Mall**		
	• Ground Level			
	➢ Discharge of main Pump	N/A	2850 LPM	N/A
	➢ Head of Main pump	N/A	88mts	N/A
	➢ Number of main pumps	N/A	02	N/A
	➢ Jockey Pump out put	N/A	280 LPM	N/A
	➢ Jockey pump head	N/A	88 mts	N/A
	➢ Standby Pump out put	N/A	2850 LPM	N/A
	➢ Standby Pump Head	N/A	88mts	N/A
	➢ Auto Starting/Manual Stopping	N/A	Provided	N/A
	➢ Pump House Access	N/A	Provided	N/A
	• Terrace level			
	➢ Discharge of pump	450 LPM	900 LPM	MR
	➢ Head of the pump	40 m	Provided	MR
	➢ Power Supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14.	**Captive Water Storage for fire-fighting**	**Provided & Maintain by Mall**		
	➢ Underground tank capacity	N/A	2,00,000 lts	N/A
	➢ Draw-off connection	N/A	Provided	N/A
	➢ Fire service inlet	Required	Provided	MR
	➢ Access to tank	N/A	Provided	N/A
	➢ Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	**Exit Signage.**	Required	Provided	MR
16.	**Provision of Lifts**			
	• Pressurization of Lift Shaft	N/A	Provided	N/A
	• Pressurization of Lift lobby	N/A	Provided	N/A
	• Communication In lift Car	N/A	Provided	N/A
	• Fireman's Grounding Switch	N/A	Provided	N/A
	• Lift Signage	N/A	Provided	N/A
17.	**Standby power supply**	Required	Provided by Mall	M/R
18.	**Refuge Area.**			

N/L6

	➢ Total Area ➢ Location	N/A N/A	N/A N/A	N/A N/A
19.	**Fire Control Room**			
	• Detector System Panel	N/A	Provided	N/A
	• Flow Switch Panel	N/A	Provided	N/A
	• PA System Panel	N/A	Provided	N/A
	• Battery backup	N/A	Provided	N/A
	• Building Floor Plans	N/A	Provided	N/A
20.	**Special Fire Protection System for Protection of special Risks, if any:**	N/A	Provided by Mall	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. Shortcomings issued by this department vide letter No. F.6/DFS/MS/EH/2026/WZ/646 dated 07.07.2026 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/SZ/2023/129 dated 21.04.2023, **renewal under rule 37** of the Delhi Fire Service Rules 2010, **is recommended**.

18/8/2026

Signature of the Inspecting Officer
Name: - R.K. Yadav
Designation: - ADO (DWK)

DO(SW)
20/8/26

DFO (WZ)
24/08/2026
Debabrata Mukherjee

CFO (WZ)
25/8/26
A.K. MALIK

Pr. Dir. CFO to issue.

Received on 8/9/26
CFO (WZ)

8/9/26
A.K. MALIK

Dy. CFO (W)
DO (SW) 8/9
ADO - DWK

ADO