C/34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2025/ 429 Dated: 12/11/2025

To

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Ref: Online application ID no. 2025102814429.

Sub: Regarding issuance of Fire Safety Certificate in respect of M/s Tata Starbucks Pvt. Ltd. (A Unit of Tata Alliance) located at Shop no. 36 & 37, Ground floor, Pacific Mall, Khayla, New Delhi-18.

Sir,

With reference to the etl.mcdonline application no. 2025102814429 on the subject cited above, it is informed that the said Eating House was visited by officer concerned of this department on 04.11.2025 in the presence of Ms Intasham (Shift Manager) and following shortcomings were observed during the inspection.

1. Alternate exit found sealed.
2. Automatic Fire Detection and Alarm System (ADAS) found non-functional.

In view of above shortcomings, this application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

11/11/25

(S. K. Dua)
Dy. Chief Fire Officer (WZ)

O/c 10/11/25.