C/86

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/304 Dated: -09/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Tashan Bar and Lounge, Plot No. 4, Block No.80A,400,401,402-27-28, Krishna Market, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026031102702 dated 11/03/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officers concerned of this department on 25/03/2026 in the presence of Sh. Rajender Kumar, Manager and following shortcomings were observed: -

1. Width of alternate exit found less than 1.5 mtr.
2. Hose reel provided but found non functional.
3. Internal Hydrant provided but found non functional.
4. Overhead water storage tank of 20,000 Ltrs found removed.
5. Terrace pump of 450 LPM found removed.
6. Diesel generator placed inside the restaurant and not protected with fire check door.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

9/4/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

O/C

Copy to: -

1. The Manager, M/s Tashan Bar and Lounge, Plot No. 4, Block No.80A,400,401,402-27-28, Krishna Market, Paharganj, New Delhi - 110055.