C/80

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No.F6/DFS/MS/EH/NDZ/2026/ 350 Dated: 22/04/2026

To

The Commissioner,
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road,
New Delhi-110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Tesoro Mio Kitchen N Kaffe located at G-13, 3rd floor, Preet Vihar, Delhi-110092.

Sir,

With reference to the elt.mcdonline application no. 2025022002168 on the subject cited above, it is informed that the said Eating House was visited by officer concerned of this department on 07/04/2026 in the presence of manager and following shortcomings was observed:

1. Alternate staircase passing through the occupied area (i.e. Kitchen).
2. All water based Systems like Fire Pumps, Hose Reels, Internal Hydrants are non- functional.
3. Standby Fire Pump having capacity of 2280 LPM & head 60 m found removed.

In view of above shortcomings, the application of renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

20/4/26

(Dr. S. K. Tomar)
Chief Fire officer

20/4/26