C-45

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/EH/NDZ/2026/199 Dated: 05/03/2026

To,

Sh. Nitin Verma
W-908, Greater Kailash,
Delhi-110048

Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s The Golden Dragon Restaurant Unit of Royal Orchid Caterers located at A- 5/11, Krishna Nagar, Shahdara, Delhi-110051.

Sir,

This has reference to MCD online application ID No. **2026012900993** dated 01/02/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 20/02/2026 in presence of Manager. The building is comprised of Ground plus three upper floors but restaurant but restaurant is running on ground floor only. The following shortcomings were observed during the time of inspection.

1. Smoke management system not provided in the restaurant.
2. First aid hose reel provided but not functional.
3. Down comer is provided but not functional.
4. Terrace pump 450 lpm head 40 meter provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

3/3/26

(Dr. S. K TOMAR)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:- o/c R.

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above

MCD ID No. **2026012900993**