C-71

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/School/SZ/2026/ 137 Dated: 27/08/2026

FIRE SAFETY CERTIFICATE (FSC)

Certified that the M/s The Indian School, located at Josip Broz Tito Marg, near Moolchand Flyover, New Delhi-110049, comprised of Basement, Ground + 03 upper floors was granted Fire Safety Certificate (FSC) by this department vide letter no.- F6/DFS/MS/School/2023/SZ/540 dated 08/08/2023 The school building was re-inspected by officer concerned of this department on 13/08/2026 in the presence of Mr. Brijesh Kumar Singh (Assist. Admin officer) and the school building/premises has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and the building (Basement + Ground + 03 upper floors) is fit for occupancy of Group B" Educational Building" with effect from ..27/08/2026 renewed for a period of Three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on....27/08/2026...at New Delhi by

27/8/26

(A. K. Malik)
Chief Fire Officer

Copy to:-.

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, M/s The Indian School, located at Josip Broz Tito Marg, Near Moolchand Flyover, New Delhi-110049.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The Basement shall be used in accordance with applicable Local Building Byelaws.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/13

INSPECTION REPORT					
1	Name & address of the building		**M/s The Indian School,** located at **Josip Broz Tito Marg, Near Moolchand Flyover, New Delhi-110049.**		
2	Building is comprised of		Basement, Ground + 03 upper floors.		
3	Type of occupancy		Group B –Educational Building		
4	Type of case		Renewal		
5	Details of previous FSC		F6/DFS/MS/School/2023/SZ/540 dated 08/08/2023		
6	Fire safety direction letter no.		F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011.		
7	Date of inspection		13/08/2026		
8	Name of the inspecting officers		Rajesh Kumar Shukla, ADO (Jangpura)		
9	Name of the designation of officer from the building side		Mr. Brijesh Kumar Singh (Admin officer)		
10	Year of construction		Not Known, Case referred through SDMC Vide letter No. D/09/AF(B)-II/CNZ/20 dated 01/06/2020		
11	Applicant's letter no.		DFS online application no. 52026051302893.		
S.No	**Minimum standard of fire prevention and fire safety U/R 33**		**Requirement as per Rules 35 (6) of DFS**	**Provided at site**	**Remarks MR/ NMR**
1	**Access to Building:**				
	A	Road width	6 m	Provided	MR
	B	Gate width	4.5 m	4.90m, 5.86m, 4.62m	MR
	C	Width of internal road	NA	NA	NA
2	**Number, Width, Type and Arrangement of Exits:**				
	A	Number of staircases			
	a	Upper floor	03 nos.	03 nos.	MR
	b	Basement	03 nos.	03 nos.	MR
	B	Width of staircases			
	a	Upper floor	1.50 m	1.50 m each	MR
	b	Basement	1.50 m	1.50 m each	MR
	C	Protection of exits			
	a	Fire check door	Required in basement	Provided	MR
	b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	02 nos.	Provided	MR
	E	Width of corridor	NA	2.36 m	NA
	F	Door size	1 m	1.10 m	MR
3	**Compartmentation:**				
	A	Fire check door	NA	NA	NA
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft door	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	**Smoke Management System:**				
	A	Basement	30 ACPH	Exhaust fans Provided	NA
	B	Upper floor	12 ACPH	NA	NA
5.	**Fire Extinguisher:**				
	A	Total numbers	Required	45 nos.	MR
	B	Types	CO_2 & ABC	CO_2 & ABC	MR
	C	ISI marking	Required	Provided	MR
6	**First-Aid-Hose Reel:**				
	A	Total numbers of each floor	02 nos.	04 nos.	MR
	B	Length of hose reel hose	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	5 mm	5 mm	MR

7	**Automatic Fire Detection and Alarming System:**				
	A	Type of detectors	NA	NA	NA
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters	NA	NA	NA
8	**MOEFA:**		NA	Provided	MR
9	**Public Address System:**		NA	Provided	MR
10	**Automatic Sprinkler System:**				
	A	Basement	Required	Provided	MR
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	**Internal Hydrants:**				
	A	Size of riser/**down-comer**	NA	100 mm	MR
	B	Number of hydrants per floor	NA	04 nos.	MR
	C	Hose box	NA	04 nos.	MR
12	**Yard Hydrants:**				
	A	Total number of hydrants	NA	06 nos.	NA
	B	Hose box	NA	06 nos.	NA
13	**Pumping Arrangements:**				
A	**Ground level**				
	a	Discharge of main pump	NA	1120 LPM	MR
	b	Head of main pump	NA	40 m	MR
	c	Number of main pumps	NA	01 no.	MR
	d	Jockey pump out put	NA	NA	NA
	e	Jockey pump head	NA	NA	NA
	f	Standby pump out put	NA	NA	NA
	g	Standby pump head	NA	NA	NA
	h	Auto starting /manual stopping	Required	Provided	MR
	i	Pump house access	NA	NA	NA
B	**Terrace Level**				
	a	Discharge of pump	900 LPM	900 LPM	MR
	b	Head of the pump	40 mtrs	40 mtrs	MR
	c	Power supply	Required	Provided	MR
	d	Auto starting of pump	Required	Provided	MR
14	**Captive Water Storage for Fire Fighting:**				
	A	Underground tank capacity	NA	40,000 Ltr	MR
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	Required	Provided	MR
	D	Access to tank	Required	Provided	MR
	E	Overhead tank capacity	15,000 ltrs	22,000 ltrs	MR
15	**Exit Signage:**		Required	Provided	MR
16	**Provision of Lifts:**				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	Required	Provided	MR
	D	Firemen's grounding switch	Required	Provided	MR
	E	Lift signage	Required	Provided	MR
17	**Standby Power Supply:**		Required	Provided (DG Set)	MR
18	**Refuge Area:**				
	A	Total area	NA	NA	NA
	B	Location	NA	NA	NA

19	**Fire Control Room:**				
	A	Detector system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	PA system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plans	NA	NA	NA
20	**Special Fire Protection systems for protection of special Risks, if any:**		NA	02 ABC Fire extinguishers provided near electric panels.	MR

LEGENDS Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested checked and found properly functional at the time of inspection.

In view of the compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/School/2023/SZ/540 dated 08/08/2023 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010.

14/8/26

Signature of the Inspecting Officer
Name: Rajesh Kumar Shukla
Designation: ADO (Jangpura)

DO (South East)

25/8/26

Ravinder Singh

CFO 8/26

20/8/26

A.K. MALIK

Pr. Dir. CFO to issue. 21/8

CFO 8/26

Received on 25/8/26

25/8/26

A.K. MALIK

DO(SE)

25/8/26

Ravinder Singh