C-117

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 274 Dated: 01/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s The Mount Shiva Dx. Lodge, 8531-8534/5, Arakashan Road, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026030502388 dated 05/03/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 12/03/2026 in the presence of Sh. Vinod Kumar, Owner and following shortcomings were observed: -

1. Smoke management system is not provided in basement.
2. Manually Operated Electronic Fire Alarm (MOEFA) provided but found non-functional.
3. Public Address System provided but found non-functional.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

30/3/26

(Dr. S. K. Tomar)
Dy. Chief Fire officer
Delhi Fire Service

Copy to: -

O/C BF

1. The Manager, M/s The Mount Shiva Dx. Lodge, 8531-8534/5, Arakashan Road, New Delhi - 110055.