C-24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/EH/2026/WZ/ 76 Dated: 23/01/2026

To

The Commissioner,
Municipal Cooperation of Delhi,
9th Floor, Dr. SPM Civic Centre,
Minto Road, New Delhi–110002

Sub: **Regarding issuance of Fire Safety Certificate in r/o M/s The Monarch by Royale (A Unit of N & K Food and Flavours) at Ground Floor, Hall No. A and B, Block-1, Garg Trade Center, Sector–11, Rohini, Delhi–110085**

Sir,

Please refer to online portal (etl.mcdonline.nic.in) application No. **2025120115285** dated 25/12/2025. In this connection, it is to inform you that the site was visited by the officers concerned of this department on 06/01/2026 in the presence of Sh. Anu (Owner). During the inspection, the shortcomings observed are as below.

1. The width of exit door found 1.20 mtr each against required width of 1.50 mtr each.
2. Fire check door (FCDs) not provided to segregate kitchen area from seating area.

In view of the above, application for issuance of fire safety certificate cannot be considered at this stage & rejected. The occupancy of the premise in the absence of requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier/management.

Yours faithfully,

23/01/26

(S.K. Dua)
Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Copy to: -

1. Ms. Nisha Lakra, M/s The Monarch by Royale (A Unit of N & K Food and Flavours) at Gd. Floor, Hall No. A and B, Block-1, Garg Trade Center, Sector–11, Rohini, Delhi–110085.