GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No. F.6/DFS/MS/FH/2026/WZ/ 199 **Dated:** 03.09.2026

FIRE SAFETY CERTIFICATE

Certified that the **The Monero A Unit By Melody Of Love Events LLP** situated at 11 No. Farm Kano 39 4 1 0 7 39 4 2 0 15 39 4 3 0 19 39 5 2 3 4 39 6 7 9 15 2 8, Village- Samalkha, Tehsil- Mehrauli, New Delhi- 11009, comprised of Ground floor & Mezzanine only, owned/occupied by **Melody Of Love Events LLP**, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010. and verified by the officers concerned of this department on dated 30/07/2026 in the presence of the Manager, and found that the building is fit for occupancy Class "D" "Assembly Building" (**for Farm House at Ground floor & Mezzanine only**) w.e.f. 03.09.2026 with a period of three years, in accordance with Rule- 36 unless renewed under Rule- 37 or sooner cancelled under Rule- 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 03.09.2026 at New Delhi.

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1 The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi: - **with a request to ensure the occupancy as detailed above and deviation, if any.**

2 Online application Id- **2026062209162 dated 10.07.2026.**

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N1

INSPECTION REPORT

1. Name & address of the building : The Monero (a unit by Melody of Love Events LLP) at 11 No. Farm Kano 39 4 1 0 7 39 4 2 0 15 39 4 3 0 19 39 5 2 3 4 39 6 7 9 15 2 8, Village- Samalkha, Tehsil- Mehrauli, New Delhi- 110097.
2. Building comprised of : Ground Floor & Mezzanine only
3. Type of Occupancy : Group D (Assembly)
4. Type of Case : New Case
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 03.08.2026
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers From the building side : Manager
10. Year of Construction : 2014 (As per online MCD application)
11. Applicant's letter No. : Online Application Id 2026062209162 dated 10.07.2026

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per BBL/UBBL	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	6.0 m	Provided	M/R
	• Gate width	4.5 m	Provided	M/R
	• Width of internal road	N/A	N/A	N/A
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	02 nos.	Provided	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	1.50 m each	Provided	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	01 nos.	Provided	MR
	f. Door Size	N/A	N/A	N/A
		1.50 m	Provided	MR
3.	**Compartmentation**			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	**Smoke Management System**			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 ACPH	Natural Ventilation	MR
5.	**Fire Extinguishers**			
	• Total numbers	12 no's	Provided	M/R
	• Types	ABC/CO_2 type	Provided	M/R
	• IS marking	ISI marked	ISI marked	M/R
6.	**First-Aid Hose Reels**			
	• Total numbers	01 Nos.	Provided	M/R
	• Length of hose reel hose	30 m	30 m	M/R
	• Nozzle diameter	5 mm	5 mm	M/R
7.	**Automatic fire detection and alarming system**			

	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	**MOEFA**	Required	Provided	M/R
9.	**Public Address System**	N/A	N/A	N/A
10.	**Automatic Sprinkler System**			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants**			
	• Size of riser/down-comer	100 mm	100 mm	M/R
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	**Yard Hydrants**			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey Pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby Pump out put	N/A	N/A	N/A
	➢ Standby Pump Head	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➢ Discharge of pump	450 LPM	450 LPM	M/R
	➢ Head of the pump	40 m	40 m	M/R
	➢ Power Supply	Required	Provided	M/R
	➢ Auto Starting of pump	Required	Provided	M/R
14.	**Captive Water Storage for fire fighting**			
	• Underground tank capacity	N/A	N/A	N/A
	➢ Draw-off connection	N/A	N/A	N/A
	➢ Fire service inlet	N/A	N/A	N/A
	➢ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 ltrs	Provided	MR
15.	**Exit Signage.**	Required	Provided	M/R
16.	**Provision of Lifts.**			**(No Lift)**
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	**Standby power supply**	Required	Provided	M/R

N/3

18.	**Refuge Area.**			
	➢ Total Area	N/A	N/A	N/A
	➢ Location	N/A	N/A	N/A
19.	**Fire Control Room**			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	**Special Fire Protection System for Protection of special Risks, if any:**	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules **it is recommended to grant Fire Safety Certificate** under Rule 35 of the Delhi Fire Service Rule 2010.

Note: - The Farm House building having 06 rooms with toilet and one pump house comprised of ground floor only and FSC issued not for temporary structure.

Signature of Inspecting Officer
Name:- R.K.Yadav
ADO (Dwarka/Bijwasan)

DO (SW)

6/8/26

DCFO (W2)

07/08/2026

CFO (W2)

7/8/26

A.K. MALIK

Dy. Dir.

CFO to issue.

12/8/26

Received on 2-8/8/26

CFO (W2)

2-8/8/26

A.K. MALIK

Dy. CFO (W)

28/08/2026

Debabrata Mukherjee

ADO (Dwk)