C-55

GOVERNMENT OF NATIONAL CAPITAL TERRITOTY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2026/WZ/ 74 Dated: 23./.01.../2026

To,

The Commissioner,
Municipal Corporation of Delhi,
E-1, 9th Floor, Dr. SPM Civic Centre, Minto Road,
New Delhi–110002
Email ID commissioner@mcd.nic.in

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s The Pratiq located at A-338, First, Second, Third Floors, Meena Bagh, Paschim Vihar, Delhi-110087

Sir,

This has reference with your MCD Portal ID 20251252015945 dated 25/12/2025 on the subject cited above. In this concerned, it is to inform you that the officer concern of this department visited the premise on 14/01/2026 in the presence of Mr. Kasav (Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Fire Cheek door found removed at main staircase.
2. First Aid Hose Reel provided but found not working.
3. Automatic fire detection & alarming system provided but found not working.
4. Manual Operated Electrical Fire Alarm (MOEFA) system found nonfunctional.
5. The Internal Hydrant provided but found not working.
6. Terrace level Fire Pump capacity of 450 LPM provided but found not working.
7. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

21/01/26

(S.K Dua)
Dy. Chief Fire Officer (WZ)

Copy to:-

1. MCD Portal ID 20251252015945 dated 25/12/2025 for uploading.