C-10

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2026/ 127 Dated: 10/08/2026

## FIRE SAFETY CERTIFICATE

Certified that **The Scholars Rosary Global School** at B - Block, Phase - 1, Shyam Vihar, Najafgarh, New Delhi - 110043 in a building comprised of Ground floor only owned / occupied by The Scholars Rosary Global School have complied with the fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by the Director of Education and verified by the officer concerned of this department on 11/07/2026 in presence of Mr. Baljeet Singh (Owner) and that the building fit for occupancy Group - B "Educational Building" with effect from 10/08/2026 for a period of **three years** in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the DFS Rule 2010 & also conditions printed below.

**Issued on** 10/08/2026 **at New Delhi by.**

10/8/26

**(A. K. Malik)**
**Chief Fire Officer**
**Delhi Fire Service**
O/C @

**Copy to: -**

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi – 110054.
2. The Principal, The Scholars Rosary Global School at B - Block, Phase - 1, Shyam Vihar, Najafgarh, New Delhi - 110043.

### Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

| INSPECTION REPORT | | | | | |
|---|---|---|---|---|---|
| 1 | Name & Address of the building | | M/s The Scholars Rosary Global School located at B – Block, Phase – 1, Shyam Vihar, Najafgarh, New Delhi – 110043. | | |
| 2 | Building is comprised of | | Ground floor only | | |
| 3 | Type of occupancy | | Educational Building (School) Group – B | | |
| 4 | Type of case | | New Case | | |
| 5 | Details of previous FSC | | Nil | | |
| 6 | Fire safety direction letter no. | | F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 | | |
| 7 | Date of inspection | | 11/07/2026 | | |
| 8 | Name of the inspecting officers | | Yashwant Singh Meena, ADO/Najafgarh | | |
| 9 | Name of the designation of officer From the building side | | Mr. Baljeet Singh (Owner) | | |
| 10 | Year of construction | | 2025 | | |
| 11 | Applicant's letter no. | | Outdoor Diary No. 2938 dated 25/06/2026 | | |
| **S. No** | **Minimum standard of Fire Prevention and Fire Safety U/R 33** | | **Circular Requirements** | **Provide at site** | **Remarks MR/NMR** |
| 1 | **Access to Building** | | | | |
| | **A** | Road width | 6.0 meters. | Provided | MR |
| | **B** | Gate width | -NA- | -NA- | -NA- |
| | **C** | Width of internal roads | -NA- | -NA- | -NA- |
| 2 | **Number, Width, Type & Arrangement of Exits** | | | | |
| | **A** | No. of staircase: | | | |
| | | a) Upper floor | -NA- | Ground floor only | -NA- |
| | | b) Basements | -NA- | -NA- | -NA- |
| | **B** | Width of the staircase: | | | |
| | | a) Upper floors | -NA- | -NA- | -NA- |
| | | b) Basements | -NA- | -NA- | -NA- |
| | **C** | Protection of Exits | | | |
| | | a) Fire check door | -NA- | -NA- | -NA- |
| | | b) Pressurization | -NA- | -NA- | -NA- |
| | **D** | No. of continuous staircase to terrace: | -NA- | -NA- | -NA- |
| | **E** | Width of the corridor | 1.80 meters | 2.45 meters | MR |
| | **F** | Door size | 1.20 meters (for class room). | 02 nos. X 1.20 meters (for class room). | MR |
| 3 | **Compartmentation:** | | | | |
| | **A** | Fire check doors | -NA- | -NA- | -NA- |
| | **B** | Sealing of horizontal & vertical opening | -NA- | -NA- | -NA- |
| | **C** | Fire rating of shaft doors | -NA- | -NA- | -NA- |
| | **D** | Water curtain | -NA- | -NA- | -NA- |
| | **E** | Fire dampers | -NA- | -NA- | -NA- |
| 4 | **Smoke management System:** | | | | |
| | **A** | Basements | -NA- | -NA- | -NA- |
| | **B** | Upper floors | -NA- | -NA- | -NA- |
| 5 | **Fire Extinguishers** | | | | |
| | **A** | Total numbers | 06 nos. | 10 nos. | MR |
| | **B** | Types | ABC & CO2 | ABC & CO2 | MR |
| | **C** | ISI marking | Required | Provided | MR |

(3)

| | | | | | |
|---|---|---|---|---|---|
| **6** | **First Aid Hose Reel** | | | | |
| | **A** | Total no. at each floor | -NA- | -NA- | -NA- |
| | **B** | Length of hose reel | -NA- | -NA- | -NA- |
| | **C** | Nozzle diameter | -NA- | -NA- | -NA- |
| **7** | **Automatic Fire Detection and Alarm System** | | | | |
| | **A** | Type of detectors | -NA- | -NA- | -NA- |
| | **B** | Location of main Panel | -NA- | -NA- | -NA- |
| | **C** | Location of repeater panel | -NA- | -NA- | -NA- |
| | **D** | Alternate power source | -NA- | -NA- | -NA- |
| | **E** | Hooter's location | -NA- | -NA- | -NA- |
| **8** | MOEFA | | -NA- | -NA- | -NA- |
| **9** | Public Address System | | -NA- | -NA- | -NA- |
| **10** | **Automatic Sprinkler System** | | | | |
| | **A** | Basement | -NA- | -NA- | -NA- |
| | **B** | Upper floor | -NA- | -NA- | -NA- |
| | **C** | Sprinklers above false ceiling | -NA- | -NA- | -NA- |
| **11** | **Internal Hydrants** | | | | |
| | **A** | Size of the riser/down comer | -NA- | -NA- | -NA- |
| | **B** | No. of hydrants per floor | -NA- | -NA- | -NA- |
| | **C** | Hose box | -NA- | -NA- | -NA- |
| **12** | **Yard Hydrants** | | | | |
| | **A** | Total no. of hydrants | -NA- | -NA- | -NA- |
| | **B** | Hose box | -NA- | -NA- | -NA- |
| **13** | **Pumping arrangements** | | | | |
| | **A** | Ground Level | | | |
| | | a) Discharge of main pump | -NA- | -NA- | -NA- |
| | | b) Head of Main Pump | -NA- | -NA- | -NA- |
| | | c) Number of Main Pump | -NA- | -NA- | -NA- |
| | | d) Jockey Pump out put | -NA- | -NA- | -NA- |
| | | e) Jockey Pump Head | -NA- | -NA- | -NA- |
| | | f) Standby Pump out put | -NA- | -NA- | -NA- |
| | | g) Standby Pump Head | -NA- | -NA- | -NA- |
| | | h) Auto Starting/ Manual stopping | -NA- | -NA- | -NA- |
| | B | Terrace Level | | | |
| | | Discharge of Pump | -NA- | -NA- | -NA- |
| | | Head of terrace pump | -NA- | -NA- | -NA- |
| | | Power supply | -NA- | -NA- | -NA- |
| | | Auto starting of pump | -NA- | -NA- | -NA- |
| **14** | **Captive Water Storage for Fire Fighting.** | | | | |
| | **A** | Underground tank capacity | -NA- | -NA- | -NA- |
| | **B** | Draw off connection | -NA- | -NA- | -NA- |
| | **C** | Fire Service Inlet | -NA- | -NA- | -NA- |
| | **E** | Access to tank | -NA- | -NA- | -NA- |
| | **D** | Overhead tank capacity | -NA- | -NA- | -NA- |
| **15** | **Exit Signage** | | Required | Provided | MR |
| **16** | **Provision of lift** | | | | |
| | **A** | Pressurization of lift shaft | -NA- | -NA- | -NA- |
| | **B** | Pressurization of lift lobby | -NA- | -NA- | -NA- |
| | **C** | Communication in lift car | -NA- | -NA- | -NA- |
| | **D** | Fireman switch | -NA- | -NA- | -NA- |
| | **E** | Lift signage | -NA- | -NA- | -NA- |
| **17** | **Standby Power Supply** | | -NA- | -NA- | -NA- |

*The Scholars Rosary Global School located at B – Block, Phase – 1, Shyam Vihar, Najafgarh, New Delhi – 110043*

| | | | | | |
|---|---|---|---|---|---|
| **18** | **Refuge Area** | | | | |
| | **A** | location | -NA- | -NA- | -NA- |
| | **B** | Total area | -NA- | -NA- | -NA- |
| **19** | **Fire Control Room** | | | | |
| | **A** | Fire Detection System panel | -NA- | -NA- | -NA- |
| | **B** | Flow switch panel | -NA- | -NA- | -NA- |
| | **C** | P A system panel | -NA- | -NA- | -NA- |
| | **D** | Battery backup | -NA- | -NA- | -NA- |
| | **E** | Building floor plan | -NA- | -NA- | -NA- |
| **20** | **Special Fire Protection for special risk if any** | | | | |
| | **A** | Special Fire Protection system for Protection of Special Risk, if any: | -NA- | -NA- | -NA- |

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under the Circular no F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011, is recommended.

22/7/2026

Signature of the Inspecting Officer
Name: Yashwant Singh Meena
Designation: ADO/Najafgarh

**D.O/SW**

23/7/26

Dy CFO (WZ)

24/07/2026

CFO (WZ)

24/07/26

Pr. Director

CFO to issue.

3/8/26

CFO (WZ)

4/8/26

A.K. MALIK

Dy. CFO (WZ)

06/03/2026

ADO (NAJ)

Sir, F.T Letter is put up for sign. Please

6/8/2026

CFO (WZ)

A.K. MALIK

M.S cell