C-15

आज़ादी का अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/SZ/2026/ 711 Dated: 22/07 /2026

To,

The Commissioner MCD,
Dr. S.P.M. Civic Centre, Minto Road,
New Delhi-110002.

Sub: Regarding issuance of FSC from fire safety point of view in r/o. M/s. The Star inn, located at Plot N. 56, first, second & third floor, Pocket-1, Jasola, New Delhi- 110025.

Sir,

Reference to online application no. – 2026061809054 dated- 18/06/2026, on the subject cited above. In this connection, it is to inform you that the premise was inspected by officer concerned of this department on 05/07/2026. in the presence of Ms. Zoufishian (Care Taker) to see the functioning of fire safety equipment's provided in the building. During inspection the following shortcomings were observed.

1. 1X1.30m & 1X1.50m staircases are provided against the requirement of 2X1.5m each.
2. First Aid Hose reels are provided but non-functional.
3. MOEFA is provided but non-functional.
4. Main fire pump capacity of 450LPM is provided but not on auto-mode.
5. Overhead water storage tank capacity of 5000ltrs provided against the requirement of 10,000ltrs.
6. Exit signages are not provided.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is cannot considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,

22/7/26

(A.K. Malik)
Chief Fire Officer

Copy to: -

1. The Owner/occupier M/s. The Star inn, located at Plot N. 56, first second & third floor, Pocket-1, Jasola, New Delhi- 110025. (online application no. – 2026061809054 dated- 18/06/2026)