GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2026/School/WZ/ 946 Dated: 20/11/2026

To

The Principal
The Vedanta School
Pooth Khurd, Delhi-110039.

Sub: - Regarding renewal of fire safety certificate in r/o The Vedanta School located Pooth Khurd, Delhi-110039.

Sir,

Please refer to your letter no. nil received in this department vide outdoor dairy no. 6127 dated 14/09/2026 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 27/10/2026 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 02 upper floors only. At the time of inspection Sh. Ashish Kumar (Manager) was also present at site. During the course of inspection, the observations/ shortcomings made are as under:-

1. Hose reel hose is provided but not functional.
2. Terrace level fire pump capacity of 450 LPM is provided but non functional.
3. Terrace level fire water tank capacity of 6,000 LTR is provided against the requirement of 10,000 LTR.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully

20/11/26

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi – 110085.