GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ 500 Dated: - 23/11/2026

To,

The Authorized Signatory,
The Veer Co-Operative Group Housing Society Ltd.,
Plot No. 28, Sector-13, Rohini, Delhi-110085.

Subj.:- Regarding renewal of fire safety certificate in respect of The Veer Co-Operative Group Housing Society Ltd., located at Plot No. 28, Sector-13, Rohini, Delhi-110085.

Sir,

This has reference to DFS online portal application no. 52026071404436 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 21/07/2026 in the presence of Sh. Kamal Kumar Jain, Owner to check compliance of shortcomings issued by this department letter no. DFS/RSD/Notice/2019-20/02 dated 24/09/2019.

During the course of inspection, it has been observed that the college management has rectified some of the shortcomings, the status is under as: -

S. no.	Shortcomings	Status
1.	Manual Call Point System found non-functional	Not yet rectified
2.	Fire Brigade inlet and draw off connection found removed	Not yet rectified
3.	Down Comer System found non-functional as terrace pumps are non-functional, landing valve/Hose reel found removed at some places	Not yet rectified
4.	Hose Box found removed	Not yet rectified
5.	Hydrant System found non-functional as pump is not working	Not yet rectified
6.	Some fireman switches found non-functional	Not yet rectified
7.	Exit signages, lift signages and floor signages found removed	Not yet rectified
8.	The direction of terrace doors on staircases are not in conformity with Building Bye Law	Not yet rectified
9.	Flower pots, vases and wreaths found kept in staircase and common circulation area, which is not in conformity with BBL-1983	Rectified

In view of the above, the application for renewal of Fire safety Certificate cannot be considered at this stage & **rejected**. You are advised to rectify the above-mentioned shortcomings under intimation to this department & till such time occupancy of the building/premises in absence of requisite fire safety arrangements shall be at your own risk and responsibility.

Yours faithfully,

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service