GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI- 110001

आजादी का अमृत महोत्सव

No. F.6/DFS/MS/SZ/2026/ 51 Dated: 16/01/2026

To,

The Manager,
M/s. Trafalagar,
Tivoli Garden, Khasra No. 646-653,
Village, Chattarpur, The Mehrauli, New Delhi- 110074.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o. M/s. Trafalagar, Tivoli Garden, Khasra No. 646-653, Village, Chattarpur, The Mehrauli, New Delhi- 110074.

Sir,

This has reference to Online application ID- 202512105552 dated 10/12/2025 on the subject cited above, it is to inform you that the site was inspected by officer concerned of this department of this department on 05/01/2026 in the presence of Mr. Mukul Manager and the following shortcomings were observed: -

1. 02 Exits of 1.0-meter width are provided against the requirements of 1.5m width each.
2. Exit signages are not provided.
3. Terrace pump not in auto mode provision.

Yours faithfully,

16/1/26
A.K. Malik
Dy. Chief Fire Officer
South Zone

Copy to: -

1. The DHO, Dy. Commissioner MCD Office, South Zone, Green Park, New Delhi.