C-166

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

आज़ादी का अमृत महोत्सव

No.F6/DFS/MS/NDZ/2025/ 587 Dated:-04./12./2025

To,

The Assistant Engineer (Elect.) - II,
Office of Assistant Engineer (Electrical) -II,
R.M.L. Elect. Division, C.P.W.D.,
Dr. R.M.L, Hospital, New Delhi-110001.

Sub: Regarding issuance of Fire NOC for Trauma Building at Dr. R.M.L. Hospital, New Delhi.

Sir,

This has reference to your letter No. 2(15)/AE(E)-II/DRMLHED/2025-26/219 dated 01/11/2025 on the subject cited above. In this connection, it is to inform you that the premises (Trauma Building, Dr. R.M.L. Hospital, New Delhi) was visited by the officers concerned of this department on 14/11/2025 in the presence of Sh. Sehdev Singh, AE (Elect.) and following shortcomings were observed.

1. All around 06 mtr. wide motorable road with 09 mtr. turning radius for fire tender movement was not provided.
2. Lifts were not protected with lift lobby.
3. Pressurization system for lift shaft, lift lobbies and staircases was not provided.
4. Automatic sprinkler system provided but found non-functional. Further, Sprinklers were not provided at some places including above false ceiling.
5. Smoke management system provided but found non-functional.
6. Hose reel provided but found non-functional.
7. Fire check doors were not provided at some places.
8. Shafts were not found sealed at some places.
9. Hoses were not provided in hose box at some places.
10. Yard hydrant found damaged at some places.
11. Overhead storage tank found was not connected with firefighting system. Further, capacity of overhead water storage was provided 30,000 Ltrs against required capacity of 50,000 Ltrs.
12. Fire pumps found not in auto mode.
13. Temporary structure provided on the terrace of 5th floor which is not shown on sanctioned plan.
14. Staircases are not continuous up to terrace level in accordance with sanctioned plan.

In view of the above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

4/12/25

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

O/C Bl