C-49

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/ 890 Dated: - 22/09/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. S.P.M. Civic Centre, Minto Road,
New Delhi -110002.

Sub.: - Regarding renewal of Fire Safety Certificate in r/o M/s Urban Banquet A Unit of Star Celebrations, located at Shop No. LGF1, Manglam Paradise Mall, Plot No. 8, Manglam Place, Sector-3, Rohini, Delhi-110085.

Sir,

This has reference to online application no. 2026081310462 dated 13/08/2026 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 30/08/2026 in the presence of Sh. Ranjeet Yadav. During inspection, it was observed that the above said restaurant is running at Lower Ground Floor only in a building comprised of basement + ground + 05 upper floors. After inspection, the following shortcoming were observed: -

1. Smoke Management System found removed.
2. First-Aid Hose Reels found damaged.
3. MOEFA found damaged.
4. Exit signages found removed

In view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage & **rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

22/9/26

(A.K. Malik)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Authorized Signatory, M/s Urban Banquet A Unit of Star Celebrations, located at Shop No. LGF1, Manglam Paradise Mall, Plot No. 8, Manglam Place, Sector-3, Rohini, Delhi-110085.