6/34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/EH/NDZ/2026/ 31 **Dated:**09/01/2026

To,

Sh. Vikas Tyagi,
M/s Viamora Foods & Hospitality LLP,
GD-21, Ground Floor, Pitampura,
Delhi-110034

Subject:- Application for issuance of Fire Safety Certificate in r/o M/s Viamora Foods & Hospitality LLP Located at GD-21, Ground Floor, Pitampura, Delhi-110034.

Sir,

This has reference to MCD application ID No. 2025121615778 dated 16/12/2025on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 27/12/2025 in presence of Sh. Nirmal (Manager). The premises is comprised of basement, ground plus three upper floors but restaurant is running ground floor only. The following shortcomings were observed during the time of inspection.

1. The second exit is passing through the kitchen.
2. Fire check door is not provided in the kitchen.
3. Fire Extinguishers are not provided.
4. First-Aid hose reel and down-comer are provided but not functional.
5. MOEFA is provided but not functional.
6. Terrace pump capacity 450 lpm provided but not functional.
7. Overhead tank capacity 10,000 liters is provided against the requirement of 20,000 liters capacity.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

09/01/26

(S. K. DUA)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

O/C R. S

Copy to:-

The Commissioner, MCD, Civic Centre, New Delhi
MCD ID No. **2025121615778**