DFA

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/GH/ECN/2026/810 Dated: -27/08/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Vijay Inn Guest House, 876, Gali Chandi Wali, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026071809910 dated 24/07/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 05/08/2026 in the presence of Mr. Raiesh Ajam, Manager and following shortcomings were observed: -

1. Hose reel found damaged in the building.
2. Automatic operation of Fire Pump found removed.
3. Exit signages found removed in the building.

Keeping in view of the above **shortcomings**, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

27/8/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

OIC BP

Copy to: -

1. The Manager, M/s Vijay Inn Guest House, 876, Gali Chandi Wali, Paharganj, New Delhi - 110055.