C-36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI–110001

No. F.6/DFS/MS/School/2025/SZ/ 869 Dated: 03/12/2025

To

The Manager,
Vinci Public School,
B-Block, 69, Patel Garden,
Kakrola Mor, Delhi–110059

Sub: Renewal of Fire Safety Certificate in r/o Vinci Public School, B-Block, 69, Patel Garden, Kakrola Mor, New Delhi–110059

Sir,

This has reference to your application (Form 'J'), dated 04/11/2025, received in this department vide outdoor diary No. 7940 dated 07/11/2025. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 24/11/2025 in the presence of Mrs. Asha (School Staff). During course of inspection, the shortcomings observed are as below.

1. Hose-reel hose found provided but non-functional.
2. Terrace level fire pump found provided but not automatic in operation.
3. Overhead water storage tank for fire-fighting found empty.

In view of the above, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify/submit compliance of the above-mentioned shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

3/12/25

(A.K. Malik)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi–110054.